



SUPPLEMENT TO CERTIFICATE

No. CF5228 & CF5229

SUPPLEMENT No. 531312

This supplement is issued as an amendment to the Certificate of which it constitutes an integral part. It should be read in conjunction with the Certificate and any other supplements in force at the time.

DOORPAC LIMITED

Unit 6 Ranskill Court, Sheffield, S9 5FZ
Tel: 01142 561615 Fax: 01142 561612

CERTIFIED PRODUCTS

Doorpac Limited – CF5228 & CF5229

SCOPE OF SUPPLEMENT

Surface Mounted Armature Plates

Surface mounted armature plates complete with a bolt through fixing are assessed for use with CF5228 and CF5229 door assemblies in accordance with the following specification:

- The armature plates shall be wholly surface mounted, with the exception of the armature bolt.
- Bolt through fixings shall be steel.
- The recess for the bolt through fixing shall be limited to a maximum 15 mm diameter, however the recess size shall be reduced, as applicable to ensure that the armature bolt is tightly fitted, whilst allowing for the intumescent protection required.
- The bolt through fixing / recess shall include intumescent protection in the form of a 1 mm thick graphite tube, to the full depth of the recess / leaf thickness.
- Maglocks components are required to be wholly surface mounted (with the exception of the armature bolt) and shall not penetrate the door to frame perimeter gaps.

All other scope relating to doorset design and configuration should comply with CF5228 and CF5229 accordingly.

Issued for and on behalf of CERTIFIRE

P Duggan – Manager
Issued: 24th May 2023
Valid to: 23rd May 2028

