



## **SUPPLEMENT TO CERTIFICATE No. CF5228 SUPPLEMENT No. S5016**

This supplement is issued as an amendment to the Certificate of which it constitutes an integral part. It should be read in conjunction with the Certificate and any other supplements in force at the time.

**Doorpac Ltd**

**2 Ranskill Court, Sheffield, S9 5FZ  
United Kingdom**  
**Tel: 0114 2561615**

### **CERTIFIED PRODUCTS**

Doorpac Ltd – CF5228

### **SCOPE OF SUPPLEMENT – BARRATT LONDON, ILDERTON ROAD**

CF5228 door assemblies as installed at the Barratt London, Ilderton Road project may include a retro fitted repair to the incorrectly positioned door viewer recesses.

The doorsets shall be of the same specification as that approved under CERTIFIRE certificate CF5228 with the following exceptions:

It is proposed that the retro fitted door viewer repairs with a maximum diameter of 16 mm will be undertaken as follows:

- The door viewer recess shall be infilled with a solid Sapele hardwood dowel with a minimum density of 640 kg/m<sup>3</sup>. The sapele dowel shall be tightly fitted within the recess.
- The Sapele hardwood dowel shall extend to the full thickness of the door leaf and shall be bonded into place using PVA adhesive.
- The plugged door viewer recesses may be capped with filler to match the decorative finish of the door leaf, ensuring that any minor gaps between the Sapele dowel and the door leaf are filled with intumescent mastic.

**All other scope relating to doorset design and configuration should comply with CF5228 accordingly.**

**Issued for and on behalf of  
CERTIFIRE**

**CXY93870-1**

**P Duggan – Manager  
Issued: 23<sup>rd</sup> July 2024  
Valid to: 22<sup>nd</sup> July 2029**



EWC-QU-FT-732 (Issue 3)

Page 1 of 1