

SUPPLEMENT TO CERTIFICATE No. CF5229 SUPPLEMENT No. S5017

This supplement is issued as an amendment to the Certificate of which it constitutes an integral part. It should be read in conjunction with the Certificate and any other supplements in force at the time.

Doorpac Ltd

2 Ranskill Court, Sheffield, S9 5FZ
United Kingdom

Tel: 0114 2561615

CERTIFIED PRODUCTS

Doorpac Ltd – CF5229

SCOPE OF SUPPLEMENT

To permit the use of steel push plates, up to 1000 mm high by 200 mm wide by 2 mm thick.

CF5229 door assemblies may incorporate steel push plates of maximum overall dimensions 1000 mm high by 200 mm wide by 2 mm thick, subject to compliance with the following requirements:

- The proposed plates shall be wholly surface mounted and bonded with thermally softening adhesives only (no mechanical fixings).
- The plates shall not wrap around the vertical leaf edges, and on the closing face shall not extend beneath the door stops.
- Plates shall not be restricted/snagged by any other building hardware item, such that the delamination of the plates would be hindered/not possible in the event of exposure to fire.
- The plates shall not occupy more than 20 % of the door leaf area in total.

All other scope relating to doorset design and configuration should comply with CF5229 accordingly.

CXY93870-1

Issued for and on behalf of CERTIFIRE



P Duggan – Manager
Issued: 7th August 2024
Valid to: 6th August 2029



EWC-QU-FT-732 (Issue 3)

Page 1 of 1