

SUPPLEMENT TO CERTIFICATE No. CF5229 SUPPLEMENT No. 504961

This supplement is issued as an amendment to the Certificate of which it constitutes an integral part. It should be read in conjunction with the Certificate and any other supplements in force at the time.

DOORPAC LIMITED

6 Ranskill Court, Sheffield, South Yorkshire, S9 5FZ Tel: 0114 256 1615

CERTIFIED PRODUCTS

Doorpac Limited - CF5229

SCOPE OF SUPPLEMENT

Addition of CERTIFIRE Approved Dropseals

Door assemblies as approved under CERTIFIRE certificate of approval, CF5229 may incorporate CERTIFIRE approved dropseals with maximum overall dimensions of 35 mm high by 14 mm wide.

CF5229 door leaves incorporating CERTIFIRE approved dropseals shall be lipped to all four edges in hardwood with a minimum density 640kg/m³ (excluding, Ash, Beech and Iroko).

Dropseals shall be fitted centrally within the bottom edge of door leaves.

All other scope relating to doorset design and configuration should comply with CF5229 accordingly.

Issued for and on behalf of CERTIFIRE

certifire UKAS

P Duggan – Manager Issued: 5th August 2021 Valid to:4th August 2026