



---

## **SUPPLEMENT TO CERTIFICATE No. CF5228**

### **SUPPLEMENT No. 524574**

---

This supplement is issued as an amendment to the Certificate of which it constitutes an integral part. It should be read in conjunction with the Certificate and any other supplements in force at the time.

**Doorpac Ltd**  
**2 Ranskill Court, Sheffield, S9 5FZ**  
**United Kingdom**  
**Tel:0114 2561615**

#### **CERTIFIED PRODUCTS**

Doorpac Ltd – CF5228

#### **SCOPE OF SUPPLEMENT**

To permit the use of CE Marked locks and latches with increased dimensions.

This appraisal considers the use of CE Marked locks and latches with increased dimensions when fitted within CF5228 door assemblies in accordance with the following specification:

- Locks and latches will be CE marked in accordance with BS EN 12209 for use on 30 minute timber fire door assemblies.
- Max lock/latch dimensions: Case: 81 mm high by 106 mm wide by 16 mm thick  
Forend: 118 mm high by 23 mm wide  
Keep: 89 mm high by 25.5 mm wide
- CF5228 assemblies shall include Intumescent protection to the lock comprising of 1 mm thick Interdens intumescent sheet material to fully wrap the lock case and behind both the forend and keep.

All other scope relating to doorset design and configuration should comply with CF5228 accordingly.

Issued for and on behalf of CERTIFIRE

P Duggan – Manager  
Issued: 29<sup>th</sup> November 2022  
Valid to: 28<sup>th</sup> November 2027

