

Certifire Notice number 47

Date: 26<sup>th</sup> July 2023

To: Certifire members

Subject: **TS10 – Alignment of Doors within Frames**

Dear Certifire Members

The purpose of this CERTIFIRE notice is to advise the requirements relating to the alignment of doors within frames.

Door leaves are required to be fitted flush with the opening face of the frame, unless the specific CERTIFIRE certificate of approval for the door assembly states otherwise.

Further to this it is noted that the door leaves may also be set back by 1 mm from the opening face of the frame.

Door leaves are not permitted to be fitted, such that the door leaf stands proud of the opening face of the frame.

To summarise door leaves shall be fitted flush with the face of the frame (+0 mm / -1 mm protrusion tolerance) unless the specific CERTIFIRE certificate of approval for the door assembly states otherwise.

TS10 shall be updated to reflect this CERTIFIRE Notice accordingly.

All certificates will be amended at the next possible update.

If you have any queries regarding Notice No. 47, please do not hesitate to contact us.

Yours sincerely,



Paul Duggan  
Certification Manager