


Briefing Note		DATE: 19/01/2026
ISSUE: 01		
PAGE: Page <b>1</b> of <b>1</b>		
No: BN205	Title: CF5228 & CF5229 Approved Screens	APPROVED: P. Brash


Following changes to Warringtonfire procedures relating to the issue & renewal of Certifire supplements to mirror certificates, Doorpac has been required to apply for Certifire Prime Door Manufacturer status. This process is now nearing conclusion.

What this means:

- All relevant current supplements will be incorporated into CF5228 & CF5229. Temporary supplements can still be issued but these will be written into the relevant certificate on update.
- The initial scope of certification is a combination of the current certificates, the relevant supplements & Falcon Timber's CF807 & CF808. So additional products are available such as double acting double doorsets.
- Notable omissions from the Falcon certificates are side screens. They are **NOT** permitted under CF807 or CF808
- Doorpac has obtained dispensation for the inclusion of modular side screens in CF5228 & CF5229 on the following basis:
  - Single acting single doorsets only
  - Side screens to be fitted into four-sided frames independent to the door frame
  - Side screens may incorporate any appropriate Certifire approved glazing system
  - Maximum side screen width 1000mm per side
  - Maximum side screen height equal to that of the door assembly
  - Side screen & door frame section widths to be equal
  - Back-to-back joints to be tightly butted together with no gaps
  - Joints can either be concealed with architrave or alternatively a maximum 3 x 3mm quirk may be incorporated
  - Side screens to incorporate 1nr full height 20 x 2mm Palusol intumescent seal in the screen jamb abutting the door frame
  - Side screens to be mechanically fixed to the door frame using a staggered twin line of steel screws from each face penetrating the adjacent element by at least half depth of the component
  - Fixings at maximum 150mm from top & bottom corners at maximum 250mm centres
  - Fanlights & over panels are **NOT** permitted in conjunction with side screens
- All new quotations including side screens should be completed to the specification noted above from week commencing 19<sup>th</sup> January 2020
- See drawings DP24059 Rev02 & DP24060 Rev02 attached



Elevation



Note:

Minimum Frame Widths To Suit Either Screen Framing Or Door Framing Depending On Which Is The Larger


Depth Of Screen Frame & Door Frame Shall Be Equal

Do Not Scale.


If In Doubt Ask!

Description: **Approved Jointing Method - Strebord FD30 Doorsets & Side Screens**

Drawn By: <b>P. Brash</b>	Approved: <b>Approved</b>	Rev:	Cert / FoA Ref: <b>CF5228</b>	Date: <b>16/01/2026</b>	Drawing No:	<b>doorpac</b> creating the perfect opening Unit 6, Ranskill Court, Sheffield, S9 5FZ
Size: See Above	Tolerance: $\pm 0.25\text{mm}$			Fire Rating:	<b>DP24059</b>	
Job No: <b>N/A</b>	© Doorpac Ltd			<b>FD30S</b>	Rev02	



Elevation



Note:

Minimum Frame Widths To Suit Either Screen Framing Or Door Framing Depending On Which Is The Larger

Depth Of Screen Frame & Door Frame Shall Be Equal

Do Not Scale.

If In Doubt Ask!

Description: **Approved Jointing Method - Strebord FD60 Doorsets & Side Screens**

Drawn By: <b>P. Brash</b>	Approved: <b>Approved</b>	Rev:	Cert / FoA Ref: <b>CF5229</b>	Date: <b>16/01/2026</b>	Drawing No:	<b>doorpac</b> creating the perfect opening Unit 6, Ranskill Court, Sheffield, S9 5FZ
Size: <b>See Above</b>	Tolerance: <b>± 0.25mm</b>			Fire Rating:	<b>DP24060</b>	
Job No: <b>N/A</b>	© Doorpac Ltd			<b>FD60S</b>	Rev02	