

70 min Eq Eq 15 32 min Hardwood\* Lip min Thickness 6mm max Thickness 25mm Hardwood\* Lip min Thickness 6mm max Thickness 25mm max

All Dimensions Are In mm Unless Stated

If In Doubt Ask!

## Notes:

Max Leaf Height: 3264mm @ 921mm Wide

Max Leaf Width: 1171mm @ 2764mm High

Door Leaf Is To Be Positioned Centrally Within The Width Of The Frame

\* - Hardwood Lippings - Min Density 650kg/m³ (Excluding Ash, Beech & Iroko)

Frame Material - Softwood or Hardwood min Density 510kg/m³

Minimum Frame Dimensions: 70mm Wide x 32mm Thick

Hanging Jambs Machined With 52mm Wide x 5mm Deep Scallop - See DP24073

Frame Intumescent Seals - Lorient Polyproducts Ltd 15mm Wide x 4mm Thick LP1504 To Frame head & 10mm Wide x 4mm Thick LP1004 To Frame Jambs

For More Information See Technical Datasheet

## Do Not Scale.

Description: CF435 & CF534 - FD30 Double Acting Single Door Assembly - Overview

Drawn By: <b>P. Brash</b>	Approved: Approved	Revision:		Date: 18/08/2025	Drawing No:	doorpac
Size: See Above	Tolerance: +/- 0.25mm		CF435	Fire Rating:	DP24072	Unit 6. Ranskill Court
Job No: N/A	© Doorpac Ltd		CF534	FD30S	Rev00	Sheffield, S9 5FZ